



- 1 CLAYTON 90G-01AB PRESSURE REDUCING VALVE OR APPROVED EQUAL (WITH EPOXY COATING AND S.S. TRIM)
- 2 ALL PIPING C.M.L.&C. STEEL PIPE 3/16"
- 3 ALL TEES, REDUCERS, VALVES, ETC. PER VID APPROVED MATERIALS TEST.

OVERLAY WITH 10 MIL. PLASTIC TO REDUCE FINES INTRUSION 36" x 36" MIN.

1% SLOPE

4" DIA. PIPE

24" x 24" x 24" SUMP WITH 3/4" GRAVEL (ACTUAL LOCATION TO BE DETERMINED IN FIELD)

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\6-6.DWG
			PRESSURE REDUCTION STATION	<i>John A. Amodeo</i> 12/2/95
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 6-4