



**NOTES**

LEGEND ON PLANS

- 1) SIZE X 1" SERVICE SADDLE
- 2) 1" BRONZE CORPORATION STOP
- 3) 1" BRONZE ANGLE METER STOP WITH LOCKWING
- 4) METER BOX (SEE STD. DWG. 1-4 FOR LOCATION) METER BOX LOCATED IN TRAVELED WAYS, PAVED AREAS, AND SIDEWALKS SHALL BE SELECTED FROM THE APPROVED MATERIAL LIST.
- 5) USE TYPE "K" COPPER TUBING FOR 1" SERVICE. (NO INTERMEDIATE JOINTS PERMITTED)
- 6) 3/8" ROCK (4" TO 6") DEEP

- A) INSTALL CATHODIC PROTECTION PER STD. DWG. 8-14
- B) ALL WATER METER OUTLETS SHALL BE LOCATED WITHIN LANDSCAPED AREAS. PLACEMENT OF OUTLETS IN PAVED AREAS REQUIRE PRIOR APPROVAL & SHALL BE IDENTIFIED ON THE IMPROVEMENT PLANS WITH THE SYMBOL \*
- C) INSTALL WARNING IDENTIFICATION TAPE

REVISIONS	APPROVED	DATE
UPDATED	B. SMITH	03/25/11
UPDATED	B. SMITH	04/11/13

VISTA IRRIGATION DISTRICT

1" WATER SERVICE

*Brian Smith* 3/16/16  
 BRIAN SMITH DATE  
 R.C.E. 39926

STD. DWG. 1-1