



NOTES:

- 1 THE DISTRICT, UPON APPLICATION BY DEVELOPER WILL FURNISH, THE METER, TWO SPOOLS & ONE GATE VALVE.
- 2 INSTALLATION SHALL BE BY THE DEVELOPER'S CONTRACTOR, INCLUDING DISTRICT FURNISHED MATERIALS IN NOTE 1. THE DEVELOPER / CONTRACTOR SHALL SUPPLY THE RP BACKFLOW ASSEMBLY (FROM THE USC LIST OF APPROVED BACKFLOW DEVICES). AND HAVE IT TESTED BY THE DISTRICT PRIOR TO PUTTING INTO SERVICE.
- 3 LOCATION OF SCM(S) SHALL BE INDICATED ON THE IMPROVEMENT PLANS.
- 4 DISTRICT WILL NOTIFY DEVELOPER WHEN HIS CONTRACTOR CAN REMOVE THE SCM & RETURN IT TO THE DISTRICT. ALL TEMPORARY PIPING FOR SCM MUST BE REMOVED, INCLUDING ALL UNDERGROUND PIPE.
- 5 THE SCM MAY BE LOCATED WITHIN THE ROADWAY UPON APPROVAL OF THE PUBLIC WORKS DEPT. OF THE AGENCY HAVING JURISDICTION OF THE SUBDIVISION AND VISTA IRRIGATION DISTRICT.
- 6 PROTECTION POSTS MAYBE REQUIRED PER STD. DWG. 4-3 IF SCM IS LOCATED IN ROADWAY.

SYMBOL ON PLANS: SCM —

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	
	J. AMODEO	12/02/99	SUBDIVISION CONSTRUCTION METER ASSEMBLY	<div style="font-family: cursive; font-size: 1.2em; margin-bottom: 5px;">Brian Smith</div> BRIAN SMITH DATE R.C.E. 39926
				STANDARD DRAWING 1-11